



**MPEC**  
PRZEMYSŁ

## TABELA REGULACYJNA 65/35°C dla instalacji centralnego ogrzewania

*Tabela regulacyjna nr 11*

Lp.	Temperatura zewnętrzna średniodobowa °C	Temperatura zasilania nośnika ciepła °C	Temperatura powrotu nośnika ciepła °C
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>
<b>1</b>	<b>-20</b>	65,0	35,0
<b>2</b>	<b>-19</b>	65,0	33,5
<b>3</b>	<b>-18</b>	65,0	32,0
<b>4</b>	<b>-17</b>	65,0	30,5
<b>5</b>	<b>-16</b>	65,0	29,0
<b>6</b>	<b>-15</b>	65,0	27,5
<b>7</b>	<b>-14</b>	65,0	26,0
<b>8</b>	<b>-13</b>	65,0	24,5
<b>9</b>	<b>-12</b>	65,0	23,0
<b>10</b>	<b>-11</b>	65,0	21,5
<b>11</b>	<b>-10</b>	65,0	20,0
<b>12</b>	<b>-9</b>	65,0	20,0
<b>13</b>	<b>-8</b>	65,0	20,0
<b>14</b>	<b>-7</b>	65,0	20,0
<b>15</b>	<b>-6</b>	65,0	20,0
<b>16</b>	<b>-5</b>	65,0	20,0
<b>17</b>	<b>-4</b>	65,0	20,0
<b>18</b>	<b>-3</b>	65,0	20,0
<b>19</b>	<b>-2</b>	65,0	20,0
<b>20</b>	<b>-1</b>	65,0	20,0
<b>21</b>	<b>0</b>	65,0	20,0
<b>22</b>	<b>1</b>	65,0	20,0
<b>23</b>	<b>2</b>	65,0	20,0
<b>24</b>	<b>3</b>	65,0	20,0
<b>25</b>	<b>4</b>	60,0	20,0
<b>26</b>	<b>5</b>	60,0	20,0
<b>27</b>	<b>6</b>	60,0	20,0
<b>28</b>	<b>7</b>	60,0	20,0
<b>29</b>	<b>8</b>	60,0	20,0
<b>30</b>	<b>9</b>	60,0	20,0
<b>31</b>	<b>10</b>	60,0	20,0
<b>32</b>	<b>11</b>	60,0	20,0
<b>33</b>	<b>12</b>	60,0	20,0

---

**ODBIORCA:**

**DOSTAWCA:**