



TABELA REGULACYJNA 90/70°C dla instalacji centralnego ogrzewania

Tabela regulacyjna nr 12

Stosowana dla parametrów obliczeniowych 90/70°C i $\Delta T = 20^\circ C$			
Lp.	Temperatura zewnętrzna średniodobowa °C	Temperatura zasilania nośnika ciepła °C	Temperatura powrotu nośnika ciepła °C
1	2	3	4
1	-20	90,0	70,0
2	-19	88,3	68,8
3	-18	86,6	67,6
4	-17	84,9	66,4
5	-16	83,2	65,2
6	-15	81,5	64,0
7	-14	79,8	62,8
8	-13	78,1	61,6
9	-12	76,4	60,4
10	-11	74,7	59,2
11	-10	73,0	58,0
12	-9	71,3	56,8
13	-8	69,6	55,6
14	-7	67,9	54,4
15	-6	66,2	53,2
16	-5	65,0	35,0
17	-4	65,0	35,0
18	-3	65,0	35,0
19	-2	65,0	35,0
20	-1	65,0	35,0
21	0	65,0	35,0
22	1	65,0	35,0
23	2	65,0	35,0
24	3	65,0	35,0
25	4	65,0	35,0
26	5	65,0	35,0
27	6	65,0	35,0
28	7	65,0	35,0
29	8	65,0	35,0
30	9	65,0	35,0
31	10	65,0	35,0
32	11	65,0	35,0
33	12	65,0	35,0

ODBIORCA:**DOSTAWCA:**