

TABELA REGULACYJNA 80/60°C dla instalacji centralnego ogrzewania

Tabela regulacyjna nr 6

Lp.	Temperatura zewnętrzna średniodobowa °C	Temperatura zasilania nośnika ciepła °C	Temperatura powrotu nośnika ciepła °C
1	2	3	4
1	-20	80,0	60,0
2	-19	78,6	59,1
3	-18	77,1	58,1
4	-17	75,7	57,2
5	-16	74,2	56,2
6	-15	72,8	55,3
7	-14	71,3	54,3
8	-13	69,9	53,4
9	-12	68,4	52,4
10	-11	67,0	51,5
11	-10	65,5	50,5
12	-9	65,0	49,6
13	-8	65,0	48,6
14	-7	65,0	47,7
15	-6	65,0	46,7
16	-5	65,0	39,0
17	-4	65,0	36,6
18	-3	65,0	34,2
19	-2	65,0	31,8
20	-1	65,0	29,4
21	0	65,0	27,0
22	1	65,0	24,6
23	2	60,0	27,2
24	3	60,0	24,8
25	4	60,0	22,4
26	5	60,0	20,0
27	6	60,0	20,0
28	7	60,0	20,0
29	8	60,0	20,0
30	9	60,0	20,0
31	10	60,0	20,0
32	11	60,0	20,0
33	12	60,0	20,0