

## TABELA REGULACYJNA 70/50°C dla instalacji centralnego ogrzewania

*Tabela regulacyjna nr 7*

Lp.	Temperatura zewnętrzna średniodobowa °C	Temperatura zasilania nośnika ciepła °C	Temperatura powrotu nośnika ciepła °C
1	2	3	4
1	-20	70,0	50,0
2	-19	69,2	49,7
3	-18	68,3	49,3
4	-17	67,5	49,0
5	-16	66,7	48,7
6	-15	65,8	48,3
7	-14	65,0	48,0
8	-13	65,0	45,5
9	-12	65,0	43,0
10	-11	65,0	40,5
11	-10	65,0	38,0
12	-9	65,0	35,5
13	-8	65,0	33,0
14	-7	65,0	30,5
15	-6	65,0	28,0
16	-5	65,0	25,5
17	-4	65,0	23,0
18	-3	65,0	20,5
19	-2	65,0	20,0
20	-1	65,0	20,0
21	0	65,0	20,0
22	1	65,0	20,0
23	2	60,0	20,0
24	3	60,0	20,0
25	4	60,0	20,0
26	5	60,0	20,0
27	6	60,0	20,0
28	7	60,0	20,0
29	8	60,0	20,0
30	9	60,0	20,0
31	10	60,0	20,0
32	11	60,0	20,0
33	12	60,0	20,0