

TABELA REGULACYJNA 65/45°C dla instalacji centralnego ogrzewania

Tabela regulacyjna nr 9

Lp.	Temperatura zewnętrzna średniodobowa °C	Temperatura zasilania nośnika ciepła °C	Temperatura powrotu nośnika ciepła °C
1	2	3	4
1	-20	65,0	45,0
2	-19	65,0	Temperatura powrotu nie wyższa niż 45°C
3	-18	65,0	
4	-17	65,0	
5	-16	65,0	
6	-15	65,0	
7	-14	65,0	
8	-13	65,0	
9	-12	65,0	
10	-11	65,0	
11	-10	65,0	
12	-9	65,0	
13	-8	65,0	
14	-7	65,0	
15	-6	65,0	
16	-5	65,0	
17	-4	65,0	
18	-3	65,0	
19	-2	65,0	
20	-1	65,0	
21	0	65,0	
22	1	65,0	
23	2	65,0	
24	3	65,0	
25	4	60,0	
26	5	60,0	
27	6	60,0	
28	7	60,0	
29	8	60,0	
30	9	60,0	
31	10	60,0	
32	11	60,0	
33	12	60,0	